

Klickitat County Port District No. 1
Change Order
 2012-01 - Fire Protection System Modifications

Date	May 2, 2012
Requester	Marc Thornsby

Title	IP Communicator Upgrade
Description	Replaces proposed Silent Knight SK series smoke detector, pull station, and input monitor modules with SD series addressable versions. Replaces proposed Silent Knight 5700 fire alarm control panel with 5808 model to allow for use of new SK-IP-2UD IP communicators. Replaces proposed IPGSM-DP IP communicators with newer SK-IP-2UD versions. Adds replacement of the existing dialer in the 118 Columbia River Building (aka Building 1D) with the newer SK-IP-2UD IP communicator).
Reason	Use of SD (versus SK) series devices will allow for the future addition of smoke detectors in the front office areas of the 110 Bingen Point Building (aka Building 1E). Use of the 5808 (versus 5700) FACP allows for the use of newer SK-IP-2UD (versus IPGSM-DP) IP communicators that support remote access and programming (limiting travel time and service charges). Adds these same remote capabilities to the existing 5820XL FACP in the 118 Columbia River Building (aka Building 1D) for the same reason.

Target Completion	n/a
Timeline Impact	None
Cost Impact	Replacement of SK series devices with SD series devices Replacement of 5700 FACP with 5808 FACP Replacement of IPGSM-DP with SK-IP-2UD IP communicator Replacement of standard dialer with SK-IP-2UD IP communicator Total additional cost: \$1,292.60

	Port of Klickitat	Performance Systems Integration (PSI)
Agreed On	May 4, 2012	May 7, 2012
Agreed By	Marc Thornsby, Executive Director	Scott Leclair, Branch Manager
(signature)	/s/ MARC D. THORNSBY	/s/ SCOTT LECLAIR

Completed On	
---------------------	--