

August 18, 2026

Addendum No. 3

PROJECT: BPBP Building 1D HVAC Replacement Project
Klickitat County Port District No, 1

Notice

This Addendum **does not** change the quote closing date of
Thursday, August 20, 2026, 2:00 p.m.
at the Port of Klickitat Administrative Offices.

Addendum No. 3 amends the Contract Documents, Specifications, and Drawings for the subject project. It is the responsibility of the prospective bidders to review the contents of this addenda and bid accordingly.

The following changes in the Contract Documents, Specifications, and Drawings constitute this addendum. All changes by addendum are to be included in the pricing on the Bid Form and the contents of addendum become a part of the Contract Documents for this project. All changes modify only the specified drawings, words, or paragraphs indicated. The balance of the Contract Documents, Specifications, and Drawings will remain in force.

CONTRACT DOCUMENTS

1. The existing Clima-Tech control system is to be used to control any and all of the proposed equipment to be installed under this contract.
The existing Clima-Tech control system is to be modified or expanded by the Contractor as required.

INFORMATIONAL AND CLARIFICATIONS

(Note: These items do not change the Contract Documents and are for the Bidder's information only.)

1. The existing HVAC control system is a Clima-Tech product. The contact is Bill Spruit, ph (503) 998-9872, email William.spruit@clima-tech.com,
2. Any proposed HVAC equipment MUST be compatible with and utilize the existing Clima-Tech control system.

IMPORTANT NOTE: Please acknowledge receipt of this Addendum in Section 00 41
13 – Bid Form under Addendum Acknowledgement on Page 15.